



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8803CT0643

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Installation systems with special pipes (PN 10): multilayer piping systems for hot and cold drinking water installations inside buildings (8803)
Product description <i>Produktbezeichnung</i>	drinking water installation system consisting of compressing connectors made of metal and multilayer pipes (PE-RT/Al/PE-RT)
Model <i>Modell</i>	Raxofix; mit SC-Contur
Test reports <i>Prüfberichte</i>	Laboratory control test: V271/22 from 27.02.2023 (IMA) Supplement test: 191101052-1 from 08.01.2021 (KIW) Type testing: 170201283-2 from 29.11.2017 (KIW) Type testing: VA KU 27323/1-E from 29.11.2017 (TGM) Type testing: VA KU 26966/2-E from 09.05.2018 (TGM) Type testing: 120005074-1 from 18.01.2018 (MPM)
Test basis <i>Prüfgrundlagen</i>	DVGW CERT PEG -W001 (31.03.2021) DVGW CERT ZP 8803 (05.03.2018) DIN CEN ISO/TS 21003-7 (01.09.2019) UBA BWGL-Metalle (11.01.2023) UBA KTW-BWGL (07.03.2022)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	09.05.2028 / 23-0349-WNV

70028 04 A DE

12.05.2023 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Raxofix	Diameter: 16,0 x 2,2 mm	
Raxofix	Diameter: 20,0 x 2,8 mm	
Raxofix	Diameter: 25,0 x 2,7 mm	
Raxofix	Diameter: 32,0 x 3,2 mm	
Raxofix	Diameter: 40,0 x 3,5 mm	
Raxofix	Diameter: 50,0 x 4,0 mm	
Raxofix	Diameter: 63,0 x 4,5 mm	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

application class and maximum operating pressure acc. to EN ISO 21003-7:
class 2/10 bar

compressing connectors with SC-Contur; function unpressed leaky; the function was tested acc. to DVGW W 534-(P)
(01.07.2015), item 4.3

The hygiene suitability for drinking water is proven with "certificates of conformity hygiene" according to "Recommendation for attestation of conformity of product hygiene suitability for drinking water" of the German Federal Environment Agency (Umweltbundesamt):

multilayer pipe:

certification body: HyCert, number: Z-339022-21-Hy102

certification body: HyCert, number: Z-339641-21-Ko

compressing connectors:

certification body: HyCert, number: Z-338011-20-Hy102