



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4350CL0159

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	gas fittings: Meter screwing (4350)
Product Description <i>Produktbezeichnung</i>	Gas meter screwing for two-pipe gas meters with integrated excess flow valve type K
Model <i>Modell</i>	2649S
Test Reports <i>Prüfberichte</i>	laboratory control test: 152983e K2020 from 11.02.2021 (GWI) laboratory control test: 152983e K2018 from 26.10.2018 (GWI) type testing: 152983eT0/16463 from 30.04.2010 (GWI)
Test Basis <i>Prüfgrundlagen</i>	DIN 3376-1 (01.02.2005)- partially

Date of Expiry / File No. 30.04.2025 / 21-0736-GNV
Ablaufdatum / Aktenzeichen

30.06.2022 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88-888
Fax +49 228 91 88-993

www.dvgw-cert.com
info@dvgw-cert.com

Gas Category	Remarks
Gasart	Bemerkungen
fuel gases according to G 260	
Type	Technical Data
2649S	nominal pressure rating: MOP 1 nominal diameter: DN 25
Typ	Bemerkungen
Remarks	
nominal data of the excess flow valves: 2,5/4/6	
Hints of Utilization / Remarks	
Verwendungshinweise / Bemerkungen	
Operation pressure: 15 up to 100 mbar	
Mounting position: vertical downward	
Connections: at the input side male thread R 1 according to DIN EN 10226-1, at the output side thread G 1 1/4 according to DIN EN ISO 228-1 for two-pipe gas meters of sizes up to G6	
Ambient temperature range: -10 up to +40 °C	

DWG