

ATTESTATION OF CONFORMITY

ISSUED TO	:	VIEGA GMBH & CO. KG Viega Platz 1, 57439 Attendorn, Germany
PRODUCT(S) DESCRIPTION	:	Fittings for the SANPRESS INOX-System
MANUFACTURED BY	:	Viega GmbH & Co. KG)
APPLICABLE STANDARD SPECIFICATIONS / REQUIREMENTS	:	Kiwa evaluation guideline BRL-K774 compression fitting to tighten with matching clamping device dated (02-10-2019)
CONFORMITY CERTIFICATE DETAILS	:	
CERTIFICATE NUMBER	:	KA87066/07
CERTIFICATE TITLE	:	PRODUCT CERTIFICATE
ISSUED BY	:	KIWA
ISSUED TO	:	VIEGA GMBH & CO. KG
EVALUATION REPORT NO	:	RA24062280

ATTESTATION

Dubai Central Laboratory Department hereby attests that the product(s) described above conforms to the requirements of the applicable standard specifications / requirements.

This attestation is based solely on the review and verification of the validity and authenticity of the Product Conformity Certificate and as per Evaluation Report as mentioned above. **This attestation shall not be used when the Product Conformity Certificate becomes invalid at any time.**



Manager-Certification and Quality Control of Products Section
Dubai Central Laboratory Department

Attestation No : VA19060057
Original Issue Date : 10-07-2019
Current Issue Date : 10-07-2024
Valid Up To : 09-07-2027

*This Attestation of Conformity is in accordance with Certification Scheme Type N as described in ISO/IEC 17067:2013
"Conformity assessment – Fundamentals of product certification and guidelines for product certification schemes."*

*This Attestation is an electronic document and shall not be reproduced except in full. Any alteration shall invalidate this document.
The Evaluation Report mentioned above including its attachments forms an integral part of this Attestation.*

	Organization/Unit: إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title: VERIFICATION AND ATTESTATION SERVICE - EVALUATION REPORT	عنوان الوثيقة:	
	Doc Ref. DM-DCLD-F-IC-6003	رقم الوثيقة:	

DETAILS OF APPLICATION AND PRODUCT:

DATE:	08 July 2024
VAS EVALUATION REPORT NO.	RA24062280
VAS APPLICATION NO.	AP24060304
APPLICANT NAME	VIEGA GMBH & CO. KG
PRODUCT DESCRIPTION	Fittings for the SANPRESS INOX-System
MANUFACTURED BY	VIEGA GMBH & CO. KG

DETAILS OF VERIFICATION AND EVALUATION:

DOCUMENT(S) VERIFIED	VERIFICATION DETAILS	RESULT	REMARKS
Product Certificate K87066/ 07 Issued in accordance with the Kiwa Regulations for product certification.	KIWA – website Product Certificate K87066/ 07 https://www.kiwa.com/en/me dia/certified-companies-andorganizations/certifiedcompanies-andorganizations/?q=K87066	Product Certificate is Valid and applicable to above product.	FITTING FOR SANPRESS INOX – SYSTEM STATEMENT BY KIWA With this product certificate , issued in accordance with the Kiwa Regulation for certification, Kiwa declares that legitimate confidence exists that the products supplied by VIEGA GMBH & CO. KG, As specified in the product certificate and marked with the Kiwa - mark in the manner as indicated in this product certficate may on delivery, be relied upon to comply with the Kiwa evaluation guideline BRL-K774 "Compression fitting to tighten with matching clamping device" dated (02-10-2019)

	Organization/Unit: إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title: VERIFICATION AND ATTESTATION SERVICE - EVALUATION REPORT	عنوان الوثيقة:	
	Doc Ref. DM-DCLD-F-IC-6003	رقم الوثيقة:	

FINAL RECOMMENDATION

It is hereby recommended to grant the Attestation Certificate to the applicant.

This recommendation is based on the full compliance with the requirements in the DM-DCLD-RD-DP33-6001 "General Rules for Verification and Attestation Service.

EVALUATED BY

Name: NEDA'A AL-AWADHI

Date: 10-07-2024

NOTED & APPROVED BY

Manager - Certification and Quality Control of
Products Section

Date: 10-07-2024

* This is an electronic document. No signatures are required.

** Attachments: **Product Certificate : K87066/07**

Date of Issue : 29/04/2024	Rev. No.: 06
Level of Confidentiality / درجة السرية: Confidential / سري	Page 2 of 2



Product certificate K87066/07

Issued 2022-05-01
Replaces K87066/06
Page 1 of 7

Fittings for the SANPRESS INOX-system

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Viega GmbH & Co. KG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K774 "Compression fittings to tighten with matching clamping device" dated 02-10-2019.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

28/180711

Kiwa Nederland B.V.
Sir Winston Churchillaan
273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company
Viega GmbH & Co. KG
Viega Platz 1
57439 ATTENDORN
Germany
Tel. +49 (0) 2722 61-0
Fax +49 (0) 2722 61-1415
info@viega.de
www.viega.de



Certification process
consists of initial and
regular assessment of:

- quality system
- product

Fittings for the SANPRESS INOX-system

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate.

2311 series, adaptor fitting

Sizes:

15 x ½
15 x ¾
18 x ½
18 x ¾
22 x ½
22 x ¾
28 x 1
28 x ¾
35 x 1
35 x 1¼
42 x 1½
54 x 2

2312 series, adaptor fitting

Sizes:

15 x ½
15 x ¾
18 x ½
18 x ¾
22 x 1
22 x ½
22 x ¾
28 x 1
28 x ¾
35 x 1¼
42 x 1½
54 x 2

2312.3 series, adaptor piece with flanged internal thread

Sizes:

15 x ½

2314.3 series, plug-in elbow 90°

Sizes:

15 x ½

2315.5 series, straight connector with SC-contur

Sizes: 15(10), 18(10), 22(10), 28(5), 35(5), 42(5) and 54 mm

2311.1 series, insert piece with external thread

Sizes:

15 x ½
18 x ½
18 x ¾
22 x ½
22 x ¾
28 x 1
35 x 1¼
42 x 1½
54 x 2

2312.1 series, insert piece with internal thread

Sizes:

15 x ½
18 x ½
18 x ¾
22 x ½
22 x ¾
28 x ¾
28 x 1
35 x 1¼
42 x 1½
54 x 2

2314 series, elbow external thread

Sizes:

15 x ½
18 x ½
18 x ¾
22 x ¾
28 x 1
35 x 1¼
42 x 1½
54 x 2

2315 series, straight connector

Sizes: 15, 18, 22, 28, 35, 42, 54

2316 series, elbow 90°

Sizes: 15, 18, 22, 28, 35, 42, 54 mm

Fittings for the SANPRESS INOX-system

2317.2 series, T-piece with SC-contur and internal thread

Sizes:

15 x ½ x 15
 18 x ½ x 18
 18 x ¾ x 18
 22 x ½ x 22
 22 x ¾ x 22
 28 x ½ x 28
 28 x ¾ x 28
 28 x 1 x 28
 35 x ½ x 35
 42 x ½ x 42
 54 x ½ x 54

2318 series, T-piece

Sizes:

15 x 15 x 15
 18 x 15 x 15
 18 x 15 x 18
 18 x 18 x 18
 22 x 15 x 15
 22 x 15 x 22
 22 x 18 x 18
 22 x 18 x 22
 22 x 22 x 15
 22 x 22 x 22
 28 x 15 x 28
 28 x 18 x 28
 28 x 22 x 22
 28 x 22 x 28
 28 x 28 x 28
 35 x 15 x 35
 35 x 18 x 35
 35 x 22 x 35
 35 x 28 x 35
 35 x 35 x 35
 42 x 18 x 42
 42 x 22 x 42
 42 x 28 x 42
 42 x 35 x 42
 42 x 42 x 42
 54 x 22 x 54
 54 x 28 x 54
 54 x 35 x 54
 54 x 42 x 54
 54 x 54 x 54

2318.1 series, insert T-piece

Sizes:

22 x 15 x 22

2325.5 series, wall plate 90° elbow

Sizes:

15 x ½
 18 x ½
 22 x ½
 22 x ¾
 28 x 1

2325.7 dubble wall plate

Sizes:

15 x ½

2326 series, elbow 45°

Sizes: 15, 18, 22, 28, 35, 42, 54 mm

2327 series, bended coupling adaptor

Sizes: 15, 18, 22

2355 series, elbow with swivel nut and internal thread

Sizes:

15 x ½
 18 x ½
 18 x ¾
 22 x 1
 22 x ¾
 28 x 1
 35 x 1¼
 42 x 1½
 54 x 2

2356 series, cap

Sizes: 15, 18, 22, 28, 35, 42, 54

2359 series, flange connector fitting with SC-contur

Sizes:

15(DN10), 18(DN15), 22(DN20), 28(DN25), 35(DN32), 42(DN40) and 54(DN50)

Fittings for the SANPRESS INOX-system

2360 series, connecting coupling with swivel nut

Sizes: 15, 22, 54, 18, 28, 35, 42

2362 series, connecting coupling with swivel nut and internal thread

Sizes:
 18 x 1/2
 22 x 1
 28 x 1
 15 x 1/2
 15 x 3/4
 18 x 3/4
 22 x 1/2
 35 x 1 1/4
 54 x 2
 28 x 3/4
 22 x 3/4
 42 x 1 1/2

2363.3 series, 90° elbow with SC-contur and union nut

Sizes:
 15 x 3/4
 28 x 1 1/4

2365 series, connecting coupling with swivel nut and external thread

Sizes:
 15 x 1/2
 15 x 3/4
 18 x 1/2
 18 x 3/4
 22 x 1/2
 22 x 3/4
 22 x 1
 28 x 3/4
 28 x 1
 35 x 1 1/4
 42 x 1 1/2
 54 x 2

2363 series, adaptor fitting

Sizes:
 15 x 1/2
 15 x 3/4
 18 x 1/2
 18 x 3/4
 22 x 3/4
 22 x 1
 28 x 1
 28 x 1 1/4
 35 x 1 1/2
 42 x 1 3/4
 42 x 2
 54 x 2 3/8
 54 x 2 1/2

2364 series, straight fitting with union nut

Sizes:
 15 x 3/4
 18 x 3/4
 22 x 1
 28 x 1 1/4
 35 x 1 1/2
 42 x 1 3/4
 54 x 2 3/8

23142 series, elbow internal thread

Sizes:
 15 x 1/2
 15 x 3/4
 18 x 1/2
 18 x 3/4
 22 x 1
 22 x 1/2
 22 x 3/4
 28 x 1
 35 x 1 1/4
 42 x 1 1/2
 54 x 2

Fittings for the SANPRESS INOX-system

23145 series, elbow internal thread

Sizes:

15 x ½
 18 x ¾
 22 x ¾
 28 x 1
 35 x 1¼

23151 series, reducer

Sizes:

18A x 15P
 22A x 15P
 22A x 18P
 28A x 18P
 28A x 22P
 28A x 15P
 35A x 22P
 35A x 28P
 35A x 18P
 42A x 35P
 42A x 22P
 42A x 28P
 54A x 42P
 54A x 28P
 54A x 35P

23155 series, straight connector

Sizes: 15, 18, 22, 28, 35, 42, 54 mm

23161 series, elbow 90°

Sizes: 15, 18, 22, 28, 35, 42, 54 mm

23171 series, T-piece with external thread

Sizes:

18 x ¾ x 18
 22 x ¾ x 22
 28 x ¾ x 28
 35 x ¾ x 35
 42 x ¾ x 42
 54 x 1¼ x 54
 54 x 1 x 54
 54 x ¾ x 54

23172 series, T-piece

Sizes:

15 x ½
 18 x ½
 18 x ¾
 22 x ½
 22 x ¾
 28 x 1
 28 x ½
 28 x ¾
 35 x ½
 42 x ½
 54 x ½

23261 series, elbow 45°

Sizes: 15, 18, 22, 28, 35, 42, 54 mm

2311XL series, adaptor piece with SC-contur and external thread

Sizes:

64.0 x 2½
 76.1 x 2½
 88.9 x 3
 108.0 x 4

2312XL series, adaptor piece with SC-contur and internal thread

Sizes:

64.0 x 2½
 76.1 x 2½
 88.9 x 3

2315XL series, straight connector with SC-contur

Sizes:

64.0, 76.1, 88.9 and 108.0 mm

2315.1XL series, reducer fitting with SC-contur

Sizes:

64.0 x 54.0
 76.1 x 54.0
 76.1 x 64.0
 88.9 x 54.0
 88.9 x 64.0
 88.9 x 76.1
 108.0 x 54.0
 108.0 x 64.0
 108.0 x 76.1
 108.0 x 88.9

Fittings for the SANPRESS INOX-system

2315.1XL series, reducer fitting

Sizes:

64.0 x 54.0
 76.1 x 54.0
 76.1 x 64.0
 88.9 x 54.0
 88.9 x 64.0
 88.9 x 76.1
 108.0 x 54.0
 108.0 x 64.0
 108.0 x 76.1
 108.0 x 88.9

2316XL series, 90° elbow with SC-contur

Sizes: 64.0, 76.1, 88.9 and 108.0 mm

2317.2XL series, T-piece with SC-contur and internal thread

Sizes:

64.0 x ¾ x 64.0
 64.0 x 2 x 64.0
 76.1 x ¾ x 76.1
 76.1 x 2 x 76.1
 88.9 x ¾ x 88.9
 88.9 x 2 x 88.9
 108.0 x ¾ x 108.0
 108.0 x 2 x 108.0

2326XL series, 45° elbow with SC-contur

Sizes: 64.0, 76.1, 88.9 and 108.0 mm

2356XL series, end cap with ¾" internal thread and SC-contur

Sizes:

64.0 x ¾
 76.1 x ¾
 88.9 x ¾
 108.0 x ¾

2356.1XL series, end cap

Sizes: 76.1, 88.9, 108.0

2315.5XL series, straight connector with SC-contur

Sizes: 64.0, 76.1, 88.9, 108.0 mm

2316.1XL series, 90° elbow with SC-contur and pipe end

Sizes: 64.0, 76.1, 88.9 and 108.0 mm

2318XL series, T-piece with SC-contur

Sizes:

64.0 x 22 x 64.0
 64.0 x 28 x 64.0
 64.0 x 35 x 64.0
 64.0 x 42 x 64.0
 64.0 x 54 x 64.0
 64.0 x 64.0 x 64.0
 76.1 x 22 x 76.1
 76.1 x 28 x 76.1
 76.1 x 35 x 76.1
 76.1 x 42 x 76.1
 76.1 x 54 x 76.1
 76.1 x 64 x 76.1
 76.1 x 76.1 x 76.1
 88.9 x 22 x 88.9
 88.9 x 28 x 88.9
 88.9 x 35 x 88.9
 88.9 x 42 x 88.9
 88.9 x 54 x 88.9
 88.9 x 64 x 88.9
 88.9 x 76.1 x 88.9
 88.9 x 88.9 x 88.9
 108.0 x 22 x 108.0
 108.0 x 28 x 108.0
 108.0 x 35 x 108.0
 108.0 x 42 x 108.0
 108.0 x 54 x 108.0
 108.0 x 64 x 108.0
 108.0 x 76.1 x 108.0
 108.0 x 88.9 x 108.0
 108.0 x 108.0 x 108.0

2326.1XL series, 45° elbow with SC-contur and pipe end

Sizes: 64.0, 76.1, 88.9 and 108.0 mm

2356XL series, end cap

Sizes: 76.1, 88.9, 108.0

2357.1XL series, end cap

Sizes: 64.0, 76.1, 88.9, 108.0

Fittings for the SANPRESS INOX-system

2359XL series, flange connector fitting with SC-contur

Sizes:

64.0(DN50), 64.0 (DN65), 76.1(DN65), 88.9(DN80),
108.0(DN100)

Fitness for contact with drinking water






This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation" dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.


MARKING

The Kiwa[®]-mark products are marked with the word mark "KIWA"  or, on very small fittings only, the abbreviated word mark  or  or  .

The fittings shall be provided with at least the following marks:

- manufacturer's name, trade name; product name or logo;
- nominal diameter.

The marking can also be applied on the package. The smallest packaging unit of the fittings (maximum of 20 pieces per package) must be provided with at least the following information:

- the word mark "KIWA"  ;
- manufacturer's name or trade name;
- nominal diameter.

The package shall be completely sealed and protected against the penetration of moisture.

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

The fittings with compression ends are being used to make tensile connections in drinking water installations with a maximum working pressure of 1000 kPa and a maximum water temperature of 90 °C. The connections can be made with stainless steel tubes according to KIWA evaluation guideline BRL-K762 and/or copper tubes according to KIWA evaluation guideline BRL-K760 in the quality "half hard" and "hard".

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Viega GmbH & Co. KG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.