



**Certificate number: 2102720**

Date issued 23rd February 2021

Date expired 22nd February 2026 Original/Amendment *Amendment*

## Kiwa UK Regulation 4 (KUKreg4) Approval

ATS3 – Without Production Surveillance

Issued by Kiwa Watertec (UK)

Evaluation Guideline: Kiwa UK – EG004  
Reference Standards: Regulators Specification  
Model Designations: see Appendix

**Manufacturer: Viega GmbH & Co. KG.**

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied on to comply with the above Evaluation Guideline and Standards, and can be marked with the KUKreg4mark.

The intended use of this certificate is for compliance with Regulation 4(1)a of the Water Supply (Water Fittings) Regulations 1999 England & Wales; 2009 Northern Ireland and 2014 Byelaws Scotland

This certificate has been issued in accordance with the Kiwa regulations for product certification, which is managed in accordance with ISO/IEC 17065.

Signed on behalf of Kiwa Watertec

David Jay,  
Business Unit Manager – Authorised Signatory  
Kiwa Watertec

CERTIFICATE

390177301

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

**Certificate issued to:**  
Viega GmbH & Co. KG.  
Viega Platz 1  
D-57439 Attendorn  
Germany



The following products are covered by this certificate -

<b>PRODUCT DESCRIPTION:</b> Range of concealed WC cistern in white plastic incorporating a BS 1212-4:2016 side entry float operated inlet valve providing a Type AG air gap arrangement and a single or dual flush outlet valve. The full flush can be set at 6 litres and the reduced flush can be set at 3 litres. The cistern also incorporates a servicing valve on the inlet supply. ATS3 – Without Production Surveillance.
<b>MODEL(S):</b> 8502.38 WC cistern (without frame); 8522.38 with dry wall frame height 1120mm; 8524.38 with dry wall frame height 1120mm; 8530.38 with dry wall frame height 980mm.
<b>SIZE:</b> ½" BSP (M) inlet connection.
<b>SCOPE:</b> Manufacturer recommended maximum working pressure 10 Bar & cold water use only. Hygienic purposes: Non-metallic materials suitable for continuous use with cold water.
<b>MATERIALS:</b> Non-Metallic materials assessed (BS6920) to backflow prevention device.
<b>BACKFLOW PROTECTION NOTES:</b> Suitable for use in a WC suite, provided it forms an arrangement which meets the requirements of Type AUK1 and an appropriate WC performance specification. Please refer to the clarification of the requirements of the Water Supply(Water Fittings) Regulations, Byelaws in Scotland, as they apply to Type AUK1 air gaps in WC suites.
<b>MARKING:</b> Viega etched in flush operating panel. 6/3 volume on backplate within cistern. Flexible hose has Lux20, DN8, PN10, 70°C & WRAS.
<b>ADDITIONAL NOTES:</b> Opacity cannot be guaranteed on this assembly.

**Extra Notes:**