



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4341BM3422

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Gas fittings: Valve combined with thermically triggered shut-off device (4341)
Product description <i>Produktbezeichnung</i>	Straight-through ball valve with thermally activated shut-off device (TAE) installed on the inlet side for gas installations
Model <i>Modell</i>	G2101T
Test reports <i>Prüfberichte</i>	Laboratory control test: 162513a K2024 from 26.01.2024 (GWI) Type testing: 162513aT0/17888 from 23.01.2020 (GWI)
Test basis <i>Prüfgrundlagen</i>	DIN EN 331 (01.04.2016) DIN 3586 (01.10.2003) DVGW CERT ZP 4110 (29.09.2022)

Date of Expiry / File No. 14.03.2029 / 24-0162-GNV
Ablaufdatum / Aktenzeichen

03.04.2024 Bd A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

i. A. W. ZL



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
Fuel gases according to G 260: 03.2013	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
G2101T	Nominal diameter: DN 15 Max. operating pressure: MOP 5 bar	
G2101T	Nominal diameter: DN 20 Max. operating pressure: MOP 5 bar	
G2101T	Nominal diameter: DN 25 Max. operating pressure: MOP 5 bar	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Connection type: internal thread Rp 1/2 to Rp 1 on both sides according to DIN 10226-1 (ISO 7-1)

Temperature class: -20°C

Ambient temperature range: -20...+60 °C

Response temperature of the TAE: +100 °C (+0/-5) K

