



KOMO®
 technical approval-with-product certificate
K50353/05



Issued 2021-06-01 Replaces K50353/04
 Valid until Indefinite Dated 2017-01-01
 Page 1 of 4

Viega PEXFIT PRO system with multilayer pipes PE-Xc/Al/PE-Xc

Viega GmbH & Co. KG

STATEMENT BY KIWA

This technical approval-with-product certificate on the basis of BRL 5610 "Plastics piping systems of PE-X/Al intended for heating installations: radiator connections" issued on 25 October 2016 by Kiwa, in accordance with the Kiwa regulations for product certification.

The quality system and the product characteristics belonging to the PEXFIT PRO system are checked periodically and the performance of the PEXFIT PRO system in the application as radiator connections is assessed. The basic principles for the assessment are checked periodically.

Based on this Kiwa declares that :

- legitimate confidence exists that the by the holder of the technical approval- with-product certificate delivered PEXFIT PRO system comply with :
 - the technical specifications as laid down in this technical approval-with-product certificate;
 - the product requirements as laid down in this technical approval-with-product certificate, provided that the PEXFIT PRO system has been marked with the KOMO®-mark in the manner as indicated in this technical approval-with-product certificate;
- the PEXFIT PRO system provides the performances as described in this KOMO technical approval-with-product certificate, provided that:
 - the application conditions and technical specifications as described in this KOMO approval-with-product certificate are met;
 - the manufacturing takes place according to the processing methods as laid down in this technical approval-with-product certificate.

Within the framework of this KOMO technical approval-with-product certificate there are no inspections with regard to the production of other parts of the PEXFIT PRO system or the processing of the PEXFIT PRO system.

Ron Scheepers
 Kiwa

This technical approval-with-product certificate is also included on the KOMO foundation websites: www.komo.nl and www.komo-online.nl.

Users of this technical approval-with-product certificate is advised to check whether it is still valid. For this purpose consult the website of Kiwa: www.kiwa.nl.

Kiwa Nederland B.V.
 Sir Winston Churchilllaan 273
 Postbus 70
 2280 AB RIJSWIJK
 The Netherlands
 Tel. +31 88 998 44 00
 Fax +31 88 998 44 20
 NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Certificate holder
 Viega GmbH & Co. KG
 Viega Platz 1
 57439 ATTENDORN
 Postfach 430/440
 57428 ATTENDORN
 Germany
 Tel. (0) 2722 61-0
 Fax (0) 2722 61-1415
 info@viega.de



Assessed is:

- Quality system
- Product
- Performance in the application
- Periodic control

CERTIFICATE

474200612

Viega PEXFIT PRO system with multilayer pipes PE-Xc/Al/PE-Xc

TECHNICAL SPECIFICATION

Subject

PEXFIT PRO system

Product characteristics

The product complies to BRL 5610 Plastics piping systems of PE-X/Al intended for heating installations: radiator connections.

The system consists of:

- PE-X/Al pipes manufactured by Viega GmbH & Co. KG (certificate K53877);
- PE-X/Al pipes manufactured by Becker Plastics GmbH (certificate K12847);
- Metal fittings manufactured by Viega GmbH & Co. KG (certificate K21483);
- PPSU fittings manufactured by Viega GmbH & Co. KG (certificate K50354);
- Protection pipes manufactured by Viega GmbH & Co. KG (certificate K12060);
- Protection pipes manufactured by Maincor Rohrsysteme GmbH & Co. KG (certificate K11408).

Specification

The dimensions of the pipe in the table below are part of this certificate.

Nominal outside diameter (mm)	Wall thickness (mm)
14	2,0
16	2,0
18	2,0
20	2,3
25	2,8
32	3,2
40	3,5
50	4,0
63	4,5

Metal and plastics fittings are used.

The connections are made by means of a special press grip.

Colour of the pipes: natural inside / white outside (diameters 14 mm – 25 mm)
black inside / white outside (diameter 32 - 63 mm)

Remarks: The pipes are also suitable for underfloor heating.

Marking

The products shall be marked with the KOMO[®] mark.

Pipes

The minimum required marking on the pipes shall be:

- KOMO (or KOMO[®] word mark) + class 5 / 10 bar;
- certificate number of accompanying technical approval-with-product certificate of the piping system;
- the manufacturer's name, trade name, system name or logo;
- material identification: PE-Xc;
- the build up of the pipe; PE-Xc/Al/PE-Xc;
- nominal outside diameter and nominal wall thickness of the pipe in mm;
- production code.

The realization of the marks is as follows: clear, durable and indelible at intervals of not more than 2 meter.



Viega PEXFIT PRO system with multilayer pipes PE-Xc/Al/PE-Xc

Fittings

The minimum required marking on the fittings shall be:

- KOMO (if not possible KOMO only on the smallest packaging);
- the manufacturer's name, trade name or logo;
- nominal outside diameter of the corresponding pipe;
- production code.

Location of the marks: on every fitting.

The realization of the marks is as follows: clear, durable and indelible.

The minimum required marking on the smallest packaging unit of the fittings shall be:

- KOMO (or KOMO[®] word mark);
- certificate number of the accompanying technical approval-with-product certificate of the piping system, according the marking of the belonging pipe;
- the manufacturer's name, trade name, system name or logo;
- material identification if the fitting body is made of plastics;
- nominal outside diameter and nominal wall thickness of the corresponding pipe in mm.

Location of the marks: on every package.

The realization of the marks is as follows: clear, durable and indelible on every packaging.

Protection pipes

The minimum required marking on the protection pipes shall be:

- KOMO (or KOMO[®] word mark);
- certificate number of the protection pipe;
- the manufacturer's name, trade name or logo.

The realization of the marks is as follows: clear, durable and indelible at intervals of not more than 2,5 m.

Logistics

Production en assembly of the system is laid down in the annex of the certification agreement.

PROCESSING

The supplier shall provide installation instructions, approved by Kiwa. A reference to these instructions shall be made at or near the packaging. The instructions are published in the Dutch language and contains at least specific information with regard to storage, transport, processing temperature and construction of the joints.

So-called "combination boilers" are often applied in individual house heating systems. In such boilers, no double separation between drinking water and heating medium exists. A leak in the single separation may result in the heating medium coming into contact with drinking water. Because of this it is important that in case additives are added to the heating medium a Kiwa product certificate for these additives has been issued.

The heat emission to the floor is dependent on the thickness of the finishing coat and the mutual distance between the pipes. The preconditions have to be clearly described in the instructions.

PERFORMANCES

1. The system is oxygen tight.
2. All joints must be leak tight and possess sufficient clamp force to resist external influences.

PERFORMANCES OF THE PRODUCTS

All system components are designed for a lifetime of 50 years at an a operating temperature profile according to class 5 of NEN-ISO 10508 and an allowable working pressure of maximum 10 bar.

The protection pipes have to protect the medium pipes in case the medium pipes are embedded.



Viega PEXFIT PRO system with multilayer pipes PE-Xc/Al/PE-Xc

RECOMMENDATIONS FOR USERS

Check at the time of delivery whether:

- the products are in accordance with the agreement;
- the mark and marking method are correct;
- the product show no visible defects as a result of e.g. transport.

Examine by delivery if the under "processing" mentioned products satisfy to this mentioned specifications.

If you should reject a product on the basis of the above, please contact:

- Viega GmbH & Co. KG
- and, if necessary:
- Kiwa Nederland B.V.

Consult the installation instructions of the producer for the correct way of storage, transport and processing of the products.

Take the application conditions mentioned under "performances" in consideration.

