



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4360BP0164

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Gas fittings: Gas flow monitor (4360)
Product description <i>Produktbezeichnung</i>	Gas flow monitor for underground service lines made of high-density polyethylene (PE-HD and PE-Xa), optionally with overflow opening
Model <i>Modell</i>	965...
Test reports <i>Prüfberichte</i>	Laboratory control test: 162133a K2023 from 18.10.2023 (GWI)
Test basis <i>Prüfgrundlagen</i>	DIN 30652-2 (01.09.2022)

Date of Expiry / File No. 15.06.2029 / 24-0379-GNV
Ablaufdatum / Aktenzeichen

08.10.2024 Koh A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
Fuel gases according to G 260: 03.2013	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
965...	Nominal flow rate: 11 (Typ R), 10 (Typ A/D und C) m ³ /h Nominal diameter: DN 25	
965...	Nominal flow rate: 16 (Typ R), 13 (Typ A/D und C) m ³ /h Nominal diameter: DN 32	
965...	Nominal flow rate: 24 (Typ R), 19 (Typ A/D und C) m ³ /h Nominal diameter: DN 40	
965...	Nominal flow rate: 34 (Typ R), 31 (Typ A/D und C) m ³ /h Nominal diameter: DN 50	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
9652.1; 9652.2	Type R; operating pressure range: 35...5000 mbar
9653.1; 9653.2	Type A/D; operating pressure range: 25...1000 mbar
9655.1; 9655.2	Type C; operating pressure range: 25...5000 mbar
...1	with overflow opening, installed in the Geopress housing with SC Contur
...2	with overflow opening, integral insert/cartridge
9653.3	without overflow opening, only in the housing with SC-Contur in the nominal size DN 25 (d32)

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Connection type: material transition connection on both sides to pipes made of PE 80, PE 100 or PE-Xa, d 32 to 63, tested according to DVGW-G 5600-1.

Ambient temperature range: -20...+60 °C.

Installation position: horizontal or vertically upwards.

