

The manufacturer is awarded the following type test approval mark in virtue of a component test report:

Category type test approval mark:

[component](#)

Technical inspection and surveillance organisation and test report:

TÜV Rheinland dated 2023-11-09

Manufacturer/Distributor:

[Viega GmbH & Co. KG](#)
[Viega Platz 1](#)
[57439 Attendorn](#)
[GERMANY](#)

Type test approval mark:

[TÜV . K . 23 - 002](#)

Design:

non-detachable pipe connection (using press connector)

Type:

[Megapress](#)
for pipe dimensions $\frac{3}{8}$ ", $\frac{1}{2}$ ", $\frac{3}{4}$ ", 1", 1 $\frac{1}{4}$ ", 1 $\frac{1}{2}$ ", 2", 2 $\frac{1}{2}$ ", 3", 4" and 38.0 mm, 44.5 mm, 57.0 mm

The award is made pursuant to:

- VdTÜV-Merkblatt Komponenten 100, edition 2017-03-20, in conjunction with TÜV-Verband-Merkblatt Allgemeines 002, edition 2022-09-20
- directive 2014/68/EU dated 15.05.2014 (Pressure Equipment Directive)
- test programme (in accordance with Annex 1 of VdTÜV-Merkblatt Komponenten 100)
- DIN EN 10216-1:2014-03
- DIN EN 10217-1:2019-08
- DIN EN 10255:2007-07

Valid until:

[2028-11-30](#)

The award may be revoked.

Note: The manufacturer or importer must task the authorised inspector with conducting a yearly random check of components from the production line to establish their conformity with the approved type.

TÜV-Verband e. V.
Friedrichstraße 136
10117 Berlin

phone: +49 30 760095-400
e-mail: bauteile@tuev-verband.de

Industry and plant engineering division

www.tuev-verband.de/en