



GAS.BE – ARGB – KVBG

The GAS.BE-ARGB-KVBG laboratory certifies the conformity with Belgian requirements for gas press fittings.

Le laboratoire de GAS.BE-ARGB certifie que les raccords à sertissage gaz sont conformes aux exigences Belges.

Het laboratorium van de GAS.BE-KVBG verklaart dat de gas persfittings conform zijn aan de Belgische eisen.

Certificate Number :

N° du certificat :

Certificaat nummer :

C-20-3712-BA

Date of issue :

Date d'édition :

Datum van aflevering :

09/12/2020

Manufacturer :

Fabricant :

Fabrikant :

Viega Technology GmbH & Co. KG

Viega Platz 1

DE- 57439 Attendorn

Distributor :

Distributeur :

Verdeler:

Viega Belgium

Planet I Business Park

Tollaan 101 c

BE- 1932 Sint-Stevens-Woluwe

Type:

Sanpress Inox G with SC-Contur

Stainless steel gas press fittings for stainless steel pipes

(according to EN 10312)

Raccords à sertissage en acier inoxydable pour tuyaux en acier inoxydable

(conforme à EN 10312)

Roestvast stalen gas persfittings voor roestvast stalen buizen

(volgens EN 10312)

MOP: 5 bar - GT: 5 bar

Diameter: 15 – 18 – 22 – 28 – 35 – 42 – 54 mm

Thread EN 10226-1 R/R_p: 1/2" – 3/4" – 1" – 5/4" – 6/4" – 2"

DN: 25

Model 0216

90° elbow, female/female end

Model 0216.1

90° elbow, female end/plain mail end

Model 0226

45° elbow, female/female end

Model 0226.1

45° elbow, female end/plain mail end

Model 0214

90° adapter elbow, female end and male thread

Model 0214.2

90° adapter elbow, female end and female thread

Model 0218

Tee, female ends

Model 0217.2

Tee, with female thread and female/female end

Model 0211

Adapter, with female end and male thread

Model 0212

Adapter, with female end and female thread

Model 0215

Coupling, female/female end

Model 0215.5

Sliding coupling, female/female end

Model 0215.1

Reducer, with female and male plain end

Model 0256

Cap, female end

Model 0225.5

Wall plate with female end and female thread

Model 2659.5

Flange adapter, female end

Equipped with B3-3785 or B3-3786 sealing

Scope :
Domaine d'application :
Toepassingsgebied :


- Low and medium pressure gas installations according to the standards NBN D51-003, NBN D51-004 and NBN D51-006
- *Installations basse et moyenne pression suivant les normes NBN D51-003, NBN D51-004 et NBN D51-006*
- Lage en midden druk gasinstallaties volgens de normen NBN D51-003, NBN D51-004 en NBN D51-006

Ø stainless steel pipe Ø tuyau acier inoxydable Ø roestvast stalen buis	15	18	22	28	35	42	54
Minimum wall thickness stainless steel pipe Epaisseur de paroi minimale du tuyau en inox Minimum wanddikte roestvast stalen buis	1	1	1,2	1,2	1,5	1,5	1,5

Requirements:
Exigences :
Eisen :

DVGW G 5614 'Unlösbare Rohrverbindungen für metallene Gasleitungen; Pressverbinder'

- DVGW Certificate – nr. DG 4550AU0070
- MPM Prüfbericht – nr. 12000131 (06.08.2020)
- MPM Prüfbericht – nr. 12005093 (07/08/2018)



Olivier THIBAUT
Laboratory Manager.