

ATTESTATION OF CONFORMITY

ISSUED TO : VIEGA GMBH & CO. KG
Viega Platz 1, 57439 Attendorn, Germany

PRODUCT(S) DESCRIPTION : SANPRESS tube 1.4521 and 1.4401
Seamless and welded stainless steel tubes for
drinking water installations

MANUFACTURED BY : Viega GmbH & Co. KG

APPLICABLE STANDARD SPECIFICATIONS : Kiwa evaluation guideline BRL-K762/03
/ REQUIREMENTS

CONFORMITY CERTIFICATE DETAILS :

CERTIFICATE NUMBER : K46428/06

CERTIFICATE TITLE : PRODUCT CERTIFICATE

ISSUED BY : KIWA

ISSUED TO : VIEGA GMBH & CO. KG

EVALUATION REPORT NO : RA24062281

ATTESTATION

Dubai Central Laboratory Department hereby attests that the product(s) described above conforms to the requirements of the applicable standard specifications / requirements.

This attestation is based solely on the review and verification of the validity and authenticity of the Product Conformity Certificate and as per Evaluation Report as mentioned above. **This attestation shall not be used when the Product Conformity Certificate becomes invalid at any time.**



Manager-Certification and Quality Control of Products Section
Dubai Central Laboratory Department

Attestation No : VA19060058
Original Issue Date : 10-07-2019
Current Issue Date : 10-07-2024
Valid Up To : 09-07-2027

*This Attestation of Conformity is in accordance with Certification Scheme Type N as described in ISO/IEC 17067:2013
"Conformity assessment – Fundamentals of product certification and guidelines for product certification schemes."*

*This Attestation is an electronic document and shall not be reproduced except in full. Any alteration shall invalidate this document.
The Evaluation Report mentioned above including its attachments forms an integral part of this Attestation.*

	Organization/Unit: إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title: VERIFICATION AND ATTESTATION SERVICE - EVALUATION REPORT	عنوان الوثيقة:	
	Doc Ref. DM-DCLD-F-IC-6003	رقم الوثيقة:	

DETAILS OF APPLICATION AND PRODUCT:

DATE:	08 July 2024
VAS EVALUATION REPORT NO.	RA24062281
VAS APPLICATION NO.	AP24060305
APPLICANT NAME	VIEGA GMBH & CO. KG
PRODUCT DESCRIPTION	Sanpress tube 1.4521 and 1.4401 Seamless and welded stainless steel tubes for drinking water installations
MANUFACTURED BY	VIEGA GMBH & CO. KG

DETAILS OF VERIFICATION AND EVALUATION:

DOCUMENT(S) VERIFIED	VERIFICATION DETAILS	RESULT	REMARKS
Product Certificate K46428/06 Issued in accordance with the Kiwa Regulations for product certification.	KIWA - website Product Certificate K46428/06 https://www.kiwa.com/en/media/certified-companies-andorganizations/certifiedcompanies-andorganizations/?q=K87066	Product Certificate is Valid and applicable to above product.	Sanpress tube 1.4521 and 1.4401 Seamless and welded stainless steel tubes for drinking water installations STATEMENT BY KIWA With this product certificate , issued in accordance with the Kiwa Regulation for certification, Kiwa declares that legitimate confidence exists that the products supplied by VIEGA GMBH & CO. KG As specified in the product certificate and marked with the Kiwa - mark in the manner as indicated in this product certfcate may on delivery, be relied upon to comply with the Kiwa evaluation guideline BRL-K762/03 "Seamless and welded stainless steel tubes for drinking water installations" dated 16-01-2018.

	Organization/Unit: إدارة مختبر دبي المركزي Dubai Central Laboratory Department	الوحدة التنظيمية:	
	Document Title: VERIFICATION AND ATTESTATION SERVICE - EVALUATION REPORT	عنوان الوثيقة:	
	Doc Ref. DM-DCLD-F-IC-6003	رقم الوثيقة:	

FINAL RECOMMENDATION

It is hereby recommended to grant the Attestation Certificate to the applicant.

This recommendation is based on the full compliance with the requirements in the DM-DCLD-RD-DP33-6001 "General Rules for Verification and Attestation Service.

EVALUATED BY

Name: NEDA'A AL-AWADHI

Date: 17-07-2024

NOTED & APPROVED BY

Manager - Certification and Quality Control of
Products Section

Date: 17-07-2024

* This is an electronic document. No signatures are required.

** Attachments: **Product Certificate : K46428/06**

Date of Issue : 29/04/2024	Rev. No.: 06
Level of Confidentiality / درجة السرية: Confidential / سري	Page 2 of 2



Product certificate K46428/06

Issued 2021-06-01
Replaces K46428/05
Page 1 of 3

SANPRESS tube 1.4521 and 1.4401 Seamless and welded stainless steel tubes for drinking water installations

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Viega GmbH & Co. KG

as specified in this product certificate and marked with the Kiwa[®]-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with Kiwa evaluation guideline BRL-K762/03 "Seamless and welded stainless steel tubes for drinking water installations" dated 16-01-2018.

Ron Scheepers
Kiwa

Publication of this certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

CERTIFICATE

28/180711

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
NL.Kiwa.info@Kiwa.com
www.kiwa.nl

Company

Viega GmbH & Co. KG
Viega Platz 1
57439 ATTENDORN
Germany
Tel. +49 (0) 2722 61-0
info@viega.de
www.viega.de



Certification process
consists of initial and
regular assessment of:

- quality system
- product

SANPRESS tube 1.4521 and 1.4401 Seamless and welded stainless steel tubes for drinking water installations

PRODUCT SPECIFICATION

The products mentioned below belong to this product certificate.

SANPRESS inox tubes 1.4521

SANPRESS inox tubes in the following diameters (mm):

15, 18, 22, 28, 35, 42, 54 mm

SANPRESS inox XL tubes in the following diameters (mm):

64.0, 76.1, 88.9 and 108 mm

SANPRESS inox tubes 1.4401

SANPRESS inox tubes in the following diameters (mm):

15, 18, 22, 28, 35, 42, 54 mm

SANPRESS inox XL tubes in the following diameters (mm):

64.0, 76.1, 88.9 and 108 mm

SANPRESS tube 1.4521 and 1.4401 Seamless and welded stainless steel tubes for drinking water installations

Fitness for contact with drinking water



This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" dated 01-07-2017 ("Materials and chemicals in the supply of drinking water and warm tap water Regulation"), published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

The Kiwa[®]-mark products are marked with the wordmark "KIWA" together with  or the abbreviated word mark .

Place of the mark:

- on the tube, with a maximum distance of 500 mm between the marks.

Compulsory specifications:

- manufacturer's name or logo;
- production date or code;
- outer diameter;
- material designation.

Method of marking:

- non-erasable;
- visible after assembly.

APPLICATION AND USE

The products are to be applied in combination with fittings meeting the requirements of BRL-K774 in drinking water installations in which a maximum working pressure of 1.0 MPa and a maximum temperature of 90 °C is permitted.

Remark: Because of risk of corrosion, it is not permitted to weld, solder or braze these pipes, as well as hot forge or bend them, unless additional requirements and specific treatment methods are formulated.

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Viega GmbH & Co. KG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's processing guidelines for the proper storage and transport methods.