



AGA CERTIFIED PRODUCT



www.jas-anz.org/register

Certificate Holder: **VIEGA GMBH & CO. KG**

ABN/ACN No. (if applicable): N/A

Agent (if applicable): **Viega Pty Ltd**

Type of Component: **Tapping Valves for Gas with Built-In Operation Shut-Off for PE Pipelines**

Model No. & Description: **Viega Geopress G Tapping Valve Model: 9690G**
(Refer www.aga.asn.au for more details)

Suitable for PE pipe sizes: 63, 90, 110, 125, 140, 160, 180, 200 & 225mm

Temperature Range: -20°C – 60°C
Pressure Rating: 1,000 kPa

Relevant Standard(s): **AS 4617 – 2018 (Inc Amdt 1)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

This Certificate is issued on the express conditions that:

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.



Client Manager

Certificate Authorised

Certificate first issued: **18 September 2023**

Certificate No: **8847**

This copy valid from: **18 September 2023**

Refer specification issue: **01**