



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6310CP0516

Registration Number
Registriernummer

| | |
|---|---|
| Field of Application <i>Anwendungsbereich</i> | products of water supply <i>Produkte der Wasserversorgung</i> |
| Owner of Certificate <i>Zertifikatinhaber</i> | Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn |
| Distributor <i>Vertreiber</i> | Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn |
| Product Category <i>Produktart</i> | Valves for drinking water: check valve (6310) |
| Product description <i>Produktbezeichnung</i> | non-return valve EA, made of stainless steel, with press connectors (press connectors with SC-Contur, leaky in the non-pressed state) |
| Model <i>Modell</i> | Easytop Inox-Rückflussverhinderer |
| Test reports <i>Prüfberichte</i> | Laboratory control test: 4-0025/22 T01 from 27.09.2022 (TZW) Type testing: RV 014/14 from 14.11.2014 (TZW) UBA Guideline/BWGL: Z-342067-21-Hy210 from 23.03.2022 (WHY) UBA Guideline/BWGL: Z-342059-21-Hy210 from 23.03.2022 (WHY) |
| Test basis <i>Prüfgrundlagen</i> | DVGW W 570-1 (01.03.2013) DIN EN 13959 (01.01.2005) UBA BWGL-Metalle: Grundwerkstoffe (11.01.2023) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007) |
| Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i> | 25.08.2029 / 24-0865-WNA |

70028-04-A-DE

02.01.2025 Bn A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvbw-cert.com

| Type Typ | Technical Data Technische Daten | Remarks Bemerkungen |
|-------------|--|------------------------|
| 2339.4 | Noise emission class: I Pressure rating: PN 10 Nominal diameter: DN 15 | |
| 2339.4 | Noise emission class: I Pressure rating: PN 10 Nominal diameter: DN 20 | |
| 2339.4 | Noise emission class: I Pressure rating: PN 10 Nominal diameter: DN 25 | |
| 2339.4 | Noise emission class: I Pressure rating: PN 10 Nominal diameter: DN 32 | |
| 2339.4 | Pressure rating: PN 10 Nominal diameter: DN 40 | |
| 2339.4 | Pressure rating: PN 10 Nominal diameter: DN 50 | |

certified Components**zertifizierte Bauteile / Werkstoffe**

| Registr. No. Registr.-Nr. | Component Bauteil (Produktart) | Model/Type Modell/Typ | Manufacturer Hersteller |
|------------------------------|--|--------------------------|----------------------------|
| HW-0804DN0058 | Components from elastomers, product group P2 | EPDM 70.10-07/EPDM | Angst + Pfister AG |
| HW-0804DN0068 | Components from elastomers, product group P2 | EPDM 70.10-02/EPDM | Angst + Pfister AG |

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

press connectors according to drinking water installation system "Sanpress Inox" made by Viega GmbH & Co. KG



DVGW
CERT