



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6606CT0651

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Gas and water tapping valves : water tapping valve (6606)
Product Description <i>Produktbezeichnung</i>	tapping valve with connections "Geopress", "Geopress K" or "Maxiplus" for drinking water supply pipelines made of PE 80, PE 100, PE-Xa, PE-Xb, PE-Xc and PVC-U
Model <i>Modell</i>	969...
Test Reports <i>Prüfberichte</i>	Laboratory control test: RA4707.225081.22 from 11.08.2022 (SKZ) Type testing: 12988/18-I from 01.03.2018 (SKZ) Type testing: 12988/18-II from 01.03.2018 (SKZ) Hygiene: Z-346582-21-Hy112 from 12.07.2021 (WHY) Hygiene: Z-338007-20-Hy102 from 17.12.2020 (WHY) Hygiene: Z-338010-20-Hy102 from 17.12.2020 (WHY)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 336-P (01.10.2013) UBA BWGL-Metalle (20.06.2022) UBA ELASTOM (16.03.2016) UBA KTW-BWGL (07.03.2022) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	01.03.2028 / 22-0747-WNV

710028 BA A DE

17.01.2023 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
969...	Pressure rating: PN 16 Nominal diameter: DN 25	
969...	Pressure rating: PN 16 Nominal diameter: DN 32	
969...	Pressure rating: PN 16 Nominal diameter: DN 40	
969...	Pressure rating: PN 16 Nominal diameter: DN 50	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
9690TW	vertical tapping; with operating shut-off

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

nominal diameters of the supply pipelines: 63 mm, 90 mm, 110 mm, 125 mm, 140 mm, 160 mm, 180 mm, 200 mm and 225 mm

Suitable for the following supply pipelines:

PE 80 and PE 100 pipes according to DVGW GW 335-Teil A2

PE-Xa pipes according to GW 335-A3

PE-Xb and PE-Xc pipes according to DVGW VP 640

PVC-U pipes according DVGW GW 335-A1