



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8501BU0124

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Installation systems and system joints (PN 10): drinking water installation system (8501)
Product description <i>Produktbezeichnung</i>	drinking water installation system consisting of compressing connectors made of metal and plastic pipes (PE-RT); unpressed leaky
Model <i>Modell</i>	Raxofix; mit SC-Contur
Test reports <i>Prüfberichte</i>	Laboratory control test: 12 7804-23-01-01 from 22.11.2023 (MPM) Type testing: 120005312-2.1 from 21.02.2019 (MPM) UBA Guideline/BWGL: Z-346626-21-Hy112 from 20.03.2023 (WHY)
Test basis <i>Prüfgrundlagen</i>	DVGW W 534-(P) (01.07.2015) DVGW CERT ZP 1000 (20.04.2022) UBA BWGL-Metalle: Grundwerkstoffe (11.01.2023) UBA KTW-BWGL (07.03.2022) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	24.04.2029 / 24-0213-WNV

706031 04-A-DE

07.05.2024 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
Raxofix	Nominal diameter: DN 10 / outer diameter 16 mm	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

to use with pipes:

plastic pipe PE-RT-type II momolayerpipe "Viega" (DW-8341CT0352) in the dimension DN10 (16 x 3,8 mm)

to use with connectors:

compressing connectors made of metal, model: Raxofix, Type: M-MK (Viega GmbH & Co. KG)