



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6310CR0068
Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega Deutschland GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Valves for drinking water: check valve (6310)
Product description <i>Produktbezeichnung</i>	check valve EA
Model <i>Modell</i>	Easytop-XL-Rückflussverhinderer
Test reports <i>Prüfberichte</i>	Laboratory control test: from 26.08.2024 (TZW) Type testing: RV 003/16 from 14.09.2016 (TZW) Type testing: RV 026/15 from 05.01.2016 (TZW)
Test basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 13959 (01.01.2005)

Date of Expiry / File No. 05.01.2031 / 25-1061-WNV
Ablaufdatum / Aktenzeichen

70028-04-A-DE

27.11.2025 Le A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

A. W. Z.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvwg-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
2239 XL; 2239.4 XL	Pressure rating: PN 10 Nominal diameter: DN 65	connections: flange 8-hole
2239 XL; 2239.4 XL	Pressure rating: PN 10 Nominal diameter: DN 80	connections: flange 8-hole
2239 XL; 2239.4 XL	Pressure rating: PN 10 Nominal diameter: DN 100	connections: flange 8-hole

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

material: red brass (CC499K) or silicium bronze (CC246E / CuSi4Zn9MnP)

Suitability for drinking water hygiene is verified with a "Hygiene confirmation of conformity" in accordance with the currently valid legal basis.



DVGW
CERT