



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4360CL0453

Registration Number
Registriernummer

| | |
|---|---|
| Field of Application <i>Anwendungsbereich</i> | products of gas supply <i>Produkte der Gasversorgung</i> |
| Owner of Certificate <i>Zertifikatinhaber</i> | Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn |
| Distributor <i>Vertreiber</i> | Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn |
| Product Category <i>Produktart</i> | Gas fittings: Gas flow monitor (4360) |
| Product description <i>Produktbezeichnung</i> | Gas flow monitor Type K with overflow opening for gas installations |
| Model <i>Modell</i> | 2647.1S/2S |
| Test reports <i>Prüfberichte</i> | Type testing: 153763aT0/16603 from 22.12.2010 (GWI) Laboratory control test: 153763a K2022 from 03.11.2022 (GWI) |
| Test basis <i>Prüfgrundlagen</i> | DIN 30652-1 (01.06.2021) |

Date of Expiry / File No. 22.12.2025 / 22-0636-GNV
Ablaufdatum / Aktenzeichen

26.02.2024 Bd A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

i.A. 20.7c



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

DWG

| Gas Category | Remarks | Gasart | Remarks |
|--|--|------------|--|
| Fuel gases according to G | | | |
| 260: 03.2013 | | | |
| Type | Technical Data | Typ | Technische Daten |
| 2647.1S/2S | Operating pressure: 15 ... 100 mbar Nominal flow rate: 2,0/3,2/4,8 m³/h Nominal diameter: DN 20 | 2647.1S/2S | Operating pressure: 15 ... 100 mbar Nominal flow rate: 2,0/3,2/4,8 m³/h Nominal diameter: DN 25 |
| 2647.1S/2S | Operating pressure: 15 ... 100 mbar Nominal flow rate: 4,8/8,0 m³/h Nominal diameter: DN 32 | 2647.1S/2S | Operating pressure: 15 ... 100 mbar Nominal flow rate: 8,0/12,8 m³/h Nominal diameter: DN 40 |
| 2647.1S/2S | Operating pressure: 15 ... 100 mbar Nominal flow rate: 8,0/12,8 m³/h Nominal diameter: DN 50 | 2647.1S | Connections: Inlet with female thread Rp..., outlet with male thread R..., each acc. to DIN EN 10226-1 |
| 2647.2S | Connections: Inlet with female thread Rp..., outlet with male thread R..., each acc. to DIN EN 10226-1 | 2647.2S | Connections: Inlet with female thread Rp..., outlet with male thread R..., each acc. to DIN EN 10226-1 |
| Hints of Utilization / Remarks | | | |
| Verwendungshinweise / Bemerkungen | | | |
| Ambient temperature: -20 ... +70 °C | | | |
| Position: Horizontal or vertical (upright) | | | |