



Certificate number: 2601728 (1)

Issued 26/01/2026  
Expires 26/01/2031

## Kiwa Regulation 4(KUKreg4) Certification

Evaluation Guideline – Kiwa UK – EG004 (issue 7) – Regulation 4(1)(a)  
Model number(s) – see Appendix

### Viega GmbH & Co KG

Kiwa Watertec declares that legitimate confidence exists in the products specified in this certificate and supplied by the above organisation be relied upon to comply with the Kiwa Evaluation Guideline referred above.

Which verifies the requirements of:

**Regulation 4(1)(a) of the Water Supply (Water Fittings) Regulations 1999 England & Wales: 2009 Northern Ireland and 2014 Byelaws Scotland.**

This certificate has been issued in accordance with the Kiwa regulations for product certification.

Signed on behalf of Kiwa Watertec

David Jay, Business Unit Manager – Authorised Signatory  
Kiwa Watertec

Replication of this certificate is allowed in its entirety.

Products are intended to be used in the UK only. For other countries, other (National) requirements will apply.

See <https://www.kiwa.com/gb/en-gb/about-kiwa/water-products/> or the QR code below to ensure that the certificate is still valid.

CERTIFICATE

Kiwa Watertec  
(A Trading Division of Kiwa Ltd)  
26A Rassau Industrial Estate  
Ebbw Vale  
Gwent  
NP23 5SD  
United Kingdom  
T +44 (0)1495 308185  
[uk.water@kiwa.com](mailto:uk.water@kiwa.com)  
[www.kiwa.co.uk](http://www.kiwa.co.uk)

#### Certificate Issued to:

Viega GmbH & Co KG  
Viega Platz 1  
57439 Attendorn  
Germany



KUKreg4

The following products belong to this certificate

<p><b>PRODUCT DESCRIPTION</b>                  Combined overflow and bath filler.                  ATS3 – Without Production Surveillance.</p>
<p><b>MODEL(S)</b>                  Multiplex Trio MT5 /Rotaplex Trio MT 5 Waste and Bath Filler:                  6141.60                  6141.70                  6141.61                  6141.71                  6141.62                  6141.72                  6161.36                  6161.43                  6161.50                  6161.60                  6161.70                  6161.51                  6161.61                  6161.71                  6161.52                  6161.62                  6161.72                  6166.41                  6166.42                  6191.31                  6191.32                  6175.1                  6175.2</p> <p>Multiplex Trio Mt 1 Combined Bath Fillers And Overflows:                  6161.2                  6161.34                  6191.11                  98917KA                  99327KA                  99371KA                  977362KA                  97364KA                  6191.12                  97639DO</p> <p>Multiplex Trio Mt9 Drain/Overflow Combined Bath Filler And Overflow:                  6170.10                  6170.11                  6170.12</p> <p>Multiplex Trio Mt7 Drain/Overflow Combined Bath Filler And Overflow:                  98834BD (chrome trim)                  98835BD (white trim)</p> <p>Multiplex Trio Mt8 Drain/Overflow Combined Bath Filler And Overflow:                  97245 (chrome trim)</p>
<p><b>SIZE:</b>                  DN40/50mm x 560mm</p>
<p><b>SCOPE:</b></p>

Manufacturer recommended maximum working pressure: Open outlet use only & maximum operating temperature 65°C Hygienic Purposes: Non-metallic materials suitable for continuous use up to 65°C.
<b>MARKING</b> Viega on body
<b>MATERIALS</b> Non-metallic materials assessed (BS6920) to point of discharge.
<b>BACKFLOW PROTECTION NOTES</b> Consideration must be made on installation to the airgap arrangement. Consider balanced supplies or appropriate backflow protection at the inlets.
<b>ADDITIONAL NOTES</b> Opacity cannot be guaranteed

**Extra Notes**