



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DW-6310BO7025**

Registration Number  
Registriernummer

|   |   |
|---|---|
| <b>Field of Application</b><br><i>Anwendungsbereich</i>               | products of water supply<br><i>Produkte der Wasserversorgung</i>  |
| <b>Owner of Certificate</b><br><i>Zertifikatinhaber</i>               | Viega GmbH & Co. KG<br>Viega Platz 1, D-57439 Attendorn   |
| <b>Distributor</b><br><i>Vertreiber</i>                               | Viega GmbH & Co. KG<br>Viega Platz 1, D-57439 Attendorn   |
| <b>Product Category</b><br><i>Produktart</i>                          | Valves for drinking water: check valve (6310)   |
| <b>Product description</b><br><i>Produktbezeichnung</i>               | Easytop-non-return valve, type EA, made of red brass or silicium bronze with compression connectors and SC-contour, unpressed leaky or with external thread according to ISO 228                  |
| <b>Model</b><br><i>Modell</i>   | Easytop-Rückflussverhinderer  |
| <b>Test reports</b><br><i>Prüfberichte</i>                            | Laboratory control test: from 27.09.2022 (TZW)<br>Type testing: RV 003/16 from 14.09.2016 (TZW)<br>Type testing: RV 014/14 from 18.12.2014 (TZW)<br>Type testing: RV 011/14 from 25.08.2014 (TZW) |
| <b>Test basis</b><br><i>Prüfgrundlagen</i>                            | DVGW W 570-1 (01.03.2013)<br>DIN EN 13959 (01.01.2005)<br>UBA BWGL-Metalle: Grundwerkstoffe (11.01.2023)<br>UBA ELASTOM (16.03.2016)<br>DVGW W 270 (01.11.2007)                                   |
| <b>Date of Expiry / File No.</b><br><i>Ablaufdatum / Aktenzeichen</i> | 21.05.2028 / 23-0084-WNV  |

7/0029 04 A DE

08.08.2023 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH  
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3  
53123 Bonn

Tel. +49 228 91 88 - 888  
Fax +49 228 91 88 - 993

www.dvgw-cert.com  
info@dvgw-cert.com

| <b>Type</b><br><i>Typ</i>                           | <b>Technical Data</b><br><i>Technische Daten</i>                             | <b>Remarks</b><br><i>Bemerkungen</i> |
|---|--|--------------------------------------|
| 2139, 2239, 2239.1, 5339,<br>2239.3, 2239.4, 5339.4 | Noise emission class: I<br>Pressure rating: PN 10<br>Nominal diameter: DN 15 |                                      |
| 2139, 2239, 2239.1, 5339,<br>2239.3, 2239.4, 5339.4 | Noise emission class: I<br>Pressure rating: PN 10<br>Nominal diameter: DN 20 |                                      |
| 2139, 2239, 2239.1, 5339,<br>2239.3, 2239.4, 5339.4 | Noise emission class: I<br>Pressure rating: PN 10<br>Nominal diameter: DN 25 |                                      |
| 2139, 2239, 2239.1, 5339,<br>2239.3, 2239.4, 5339.4 | Noise emission class: I<br>Pressure rating: PN 10<br>Nominal diameter: DN 32 |                                      |
| 2139, 2239, 2239.1, 5339,<br>2239.3, 2239.4, 5339.4 | Pressure rating: PN 10<br>Nominal diameter: DN 40                            |                                      |
| 2139, 2239, 2239.1, 5339,<br>2239.3, 2239.4, 5339.4 | Pressure rating: PN 10<br>Nominal diameter: DN 50                            |                                      |

| <b>Type Variation</b><br><i>Ausführungsvariante</i> | <b>Explanations</b><br><i>Erläuterungen</i>  |
|---|--|
| 2139  | type of connection: Sanfix P-compression connectors with SC-contour, unpressed leaky |
| 2239; 2239.4  | type of connection: Sanpress-compression connectors with SC-contour, unpressed leaky |
| 2239.1; 2239.3                                      | type of connection: external thread G according to EN ISO 228                        |
| 5339; 5339.4  | type of connection: Raxofix-compression connectors with SC-contour, unpressed leaky  |

#### **Hints of Utilization / Remarks**

##### **Verwendungshinweise / Bemerkungen**

material: red brass (CC499K) or silicium bronze (CC246E / CuSi4Zn9MnP)

DVG