



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DV-7301BS0411
Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Stainless tubes: Stainless steel tube (7301)
Product description <i>Produktbezeichnung</i>	Sanpress-tube, material: 1.4401, elongate welded stainless steel tubes for the drinking water and gas installation
Model <i>Modell</i>	Sanpress-Rohr 1.4401
Test reports <i>Prüfberichte</i>	Type testing: 12 7804-23-06-PB from 28.11.2023 (MPM)
Test basis <i>Prüfgrundlagen</i>	DVGW GW 541 (01.10.2004) UBA BWGL-Metalle: Grundwerkstoffe (10.06.2024)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	01.08.2027 / 24-0331-WNR

70028-04-A-DE

08.01.2025 Bn A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvwg-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Sanpress-Rohr 1.4401	Manufacturing group: 12 up to 108 mm	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

tested dimensions acc. to DVGW GW 541 table 3: 12,0 mm; 15,0 mm; 22,0 mm; 28,0 mm; 35,0 mm; 42,0 mm; 54,0 mm; 64,0 mm; 76,1 mm; 88,9 mm and 108,0 mm

The logo for DVGW CERT, featuring a stylized leaf-like symbol above the text 'DVGW' and 'CERT' separated by a horizontal line.