



Product certificate K82663/03



Issued 2019-02-15

Replaces K82663/02

Page 1 of 2

PB-H Smartloop Pipe

STATEMENT BY KIWA

With this product certificate, issued in accordance with the Kiwa Regulations for Product Certification, Kiwa declares that legitimate confidence exists that the products supplied by

Viega Technology GmbH & Co. KG

as specified in this product certificate and marked with the Kiwa®-mark in the manner as indicated in this product certificate may, on delivery, be relied upon to comply with the Regeling materialen en chemicaliën drink- en warm tapwatervoorziening (Materials and chemicals in the supply of drinking water and warm tap water Regulation).

Ronald Karel
Kiwa

Publication of the certificate is allowed.

Advice: consult www.kiwa.nl in order to ensure that this certificate is still valid.

Kiwa Nederland B.V.

Sir Winston Churchillaan 273
Postbus 70
2280 AB RIJSWIJK
The Netherlands
Tel. +31 88 998 44 00
Fax +31 88 998 44 20
info@kiwa.nl
www.kiwa.nl

Company

Viega Technology GmbH & Co. KG
Viega Platz 1
57439 ATTENDORN
Germany
Tel +49 (0)2722 / 61-0
Fax +49 (0)2722 / 61-1415
info@viega.de
www.viega.de

Production Location

Viega Supply Chain GmbH & Co. KG
Bernrieder Straße 12
94559 Niederwinkling
Germany



Certification process
consists of initial and
regular assessment of:

- quality system
- product

PB-H Smartloop Pipe

PRODUCT SPECIFICATION

This certificate covers the PB-H inner pipe of the Viega Smartloop piping system for the transport of cold and heated drinking water.

FITNESS FOR CONTACT WITH DRINKING WATER

This product is approved on the basis of the requirements for hygienic aspects set in the "Regeling materialen en chemicaliën drink- en warm tapwatervoorziening" ("Materials and chemicals in the supply of drinking water and warm tap water Regulation", dated 01-07-2017; published in the Government Gazette).

These hygienic aspects are based on two main criteria. The product shall permanently comply with:

- The product recipe approved during the assessment procedure. This recipe is not to be changed without prior approval by Kiwa according to the Kiwa approval procedure for the hygienic aspects;
- Specific product requirements for the hygienic aspects.

The recipe and specific product requirements are laid down in the for confidentiality reasons undisclosed 'appendix hygienic aspects' to this certificate.

MARKING

Design of the required Kiwa certification mark:

- "kiwa ", in ink or seal.

Location of the mark:

- On the product / On the packaging / On the delivery receipt.

Mandatory marks:

- "kiwa ";
- "PB-H Smartloop Pipe";
- "K82663".

RECOMMENDATIONS FOR CUSTOMERS

Check at the time of delivery whether:

- the supplier has delivered in accordance with the agreement;
- the mark and the marking method are correct;
- the products show no visible defects as a result of transport etc.

If you should reject a product on the basis of the above, please contact:

- Viega Technology GmbH & Co. KG
- and, if necessary,
- Kiwa Nederland B.V.

Consult the supplier's (processing) guidelines for the proper storage and transport methods.

Check whether this certificate is still valid by consulting www.kiwa.nl.