



**CERT**

# DVGW type examination certificate

## DVGW-Baumusterprüfzertifikat

**DW-6316CP0505**

Registration Number  
Registrierenummer

|   |  |
|---|--|
| <b>Field of Application</b><br><i>Anwendungsbereich</i>               | products of water supply<br><i>Produkte der Wasserversorgung</i>   |
| <b>Owner of Certificate</b><br><i>Zertifikathaber</i>                 | Viega GmbH & Co. KG<br>Viega Platz 1, D-57439 Attendorn  |
| <b>Distributor</b><br><i>Vertreiber</i>                               | Viega GmbH & Co. KG<br>Viega Platz 1, D-57439 Attendorn  |
| <b>Product Category</b><br><i>Produktart</i>                          | valves for drinking water: Sampling valve in the drinking water installation (6316)  |
| <b>Product Description</b><br><i>Produktbezeichnung</i>               | Sampling valve in the drinking water installation  |
| <b>Model</b><br><i>Modell</i>   | 2223...  |
| <b>Test Reports</b><br><i>Prüfberichte</i>                            | laboratory control test: from 01.02.2021 (TZW)<br>laboratory control test: EV 001/19 from 21.03.2019 (TZW)<br>type testing: 120004494-1 from 18.12.2014 (MPM)<br>type testing: 120004494-2 from 18.12.2014 (MPM)<br>UBA-Guideline: KA 0233/16 from 14.07.2016 (TZW)<br>hygienic testing: MO 254/16 from 16.05.2017 (TZW) |
| <b>Test Basis</b><br><i>Prüfgrundlagen</i>                            | DIN 35860 (01.11.2020)<br>UBA BWGL-Metalle (14.05.2020)<br>UBA ELASTOM (16.03.2016)<br>UBA Übergangsregelung KTW-BWGL (10.07.2020)<br>DVGW W 270 (01.11.2007)  |
| <b>Date of Expiry / File No.</b><br><i>Ablaufdatum / Aktenzeichen</i> | 18.12.2027 / 22-0770-WNV   |

70028 04 A DE

16.11.2022 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body  
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

*G. Schmidt*



Deutsche  
Akkreditierungsstelle  
D-ZE-16028-01-05

DVGW CERT GmbH  
Zertifizierungsstelle  
Josef-Wirmer-Str. 1-3  
53123 Bonn  
Tel: +49 228 91 88 - 888  
Fax +49 228 91 88 - 993  
www.dvgw-cert.com  
info@dvgw-cert.com

| Type<br>Typ              | Technical Data<br>Technische Daten                        | Remarks<br>Bemerkungen  |
|--------------------------|---|---|
| 2223.4                   | nominal pressure rating: PN 10<br>nominal diameter: DN 10 | Sampling valve (without detachable actuation unit), connection thread: G 1/4 and adapter coupling G 3/8               |
| 2223.1 (2223.2 + 2223.3) | nominal pressure rating: PN 10<br>nominal diameter: DN 10 | Sampling valve consisting of valve (2223.2) and detachable actuation unit (2223.3), connection thread: G 1/4 or G 3/8 |

**Hints of Utilization / Remarks**
**Verwendungshinweise / Bemerkungen**

material: red brass (CC499K) or silicium bronze (CC246E / CUSI4Zn9MnP)

DWG