



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-7631CS0226

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	metal pipe unions and joints : metal pressing joint (7631)
Product Description <i>Produktbezeichnung</i>	pressing joint made of red brass without supporting sleeve for pipes made of PE-HD (PE 80, PE 100) or PE-Xa for the drinking water supply
Model <i>Modell</i>	Geopress
Test Reports <i>Prüfberichte</i>	laboratory control test: 120000428-21-3IB from 12.08.2021 (MPM) laboratory control test: 120000428-21-3PB from 12.08.2021 (MPM) type testing: 120004947 from 18.07.2017 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW GW 335-B4/(P) (01.04.2014) DIN 8076 (01.09.2013) UBA BWGL-Metalle (14.05.2020) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	18.07.2027 / 22-0518-WNV

70009 04 A 01 DE



G. Schmidt

09.08.2022 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
96	nominal diameter: 25 mm	
96	nominal diameter: 32 mm	
96	nominal diameter: 40 mm	
96	nominal diameter: 50 mm	
96	nominal diameter: 63 mm	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

The joints can get used with PE-HD pipes (PE 80, PE 100) according to DVGW GW 335-A2 and for PE-Xa pipes according to DVGW GW 335-A3.