

DVGW CERT Conformity Certificate

DVGW CERT Konformitätsbescheinigung

AS-0605CR0159

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products for safe connection to the water supply <i>Anschlusssichere Produkte für das Trinkwassernetz</i>
Manufacturer <i>Hersteller</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	devices connected to drinking water installation: products for domestic use (0605)
Product Description <i>Produktbezeichnung</i>	flushing valve universal
Model <i>Modell</i>	2243.10
Test Reports <i>Prüfberichte</i>	laboratory control test: from 30.08.2021 (TZW) laboratory control test: from 20.03.2019 (TZW) type testing: FA 010/16 from 15.06.2016 (TZW)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 540-VP (01.08.2010)


This product may be connected directly to the drinking water installation. The requirements for protection of drinking water against pollutions due to reflux are in compliance with DIN EN 1717.

Date of Expiry / File No. 15.06.2025 / 22-0402-WNV
Ablaufdatum / Aktenzeichen

DVGW

28.07.2022 Fk A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DAkkS
Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

DVGW

Type	Technical Data	Remarks
Typ	Technische Daten	Bemerkungen
2243.10	type of protection unit: free outlet type AB	
Hints of Utilization / Remarks <i>Verwendungshinweise / Bemerkungen</i>		
connection diameter: DN 20, internal thread G 1" The required protective device according to DIN EN 1717 is integral part of the tested component. All materials in contact with drinking water are hygienic harmless up to the protection point. This DVGW test certificate does not make any statements about the operation of the tested product.		