



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-7521CP0098

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Material transition fittings: Plastic connector for the transition to PE gas pipes (7523)
Product description <i>Produktbezeichnung</i>	Material transition fitting made of plastic with supporting sleeve on PE-HD pipes (PE 80, PE 100, PE-Xa)
Model <i>Modell</i>	Geopress K Gas
Test reports <i>Prüfberichte</i>	Type testing: 122000445-PB from 15.05.2023 (MPM)
Test basis <i>Prüfgrundlagen</i>	DVGW G 5600-2/(VP) (01.09.2015)

Date of Expiry / File No. 14.04.2025 / 22-0544-GNA
Ablaufdatum / Aktenzeichen

70028 04 A 01 E

20.06.2023 Fk A-1/2

id. v. 72
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888

Fax +49 228 91 88 - 993

www.dvgw-cert.com

info@dvgw-cert.com

Gas Category	Remarks
<i>Gasart</i>	<i>Bemerkungen</i>

Fuel gases acc. to G 260 excl.
5. family

Type	Technical Data	Remarks
<i>Typ</i>	<i>Technische Daten</i>	<i>Bemerkungen</i>

Geopress K Gas	Nominal diameter: 32 mm	
Geopress K Gas	Nominal diameter: 40 mm	
Geopress K Gas	Nominal diameter: 50 mm	
Geopress K Gas	Nominal diameter: 63 mm	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Maximum operation pressure: 5 bar (PE 80, SDR 11), 8 bar (PE-Xa, SDR 11) or 10 bar (PE 100, SDR 11). For the transition joints maximum 5 bar

Connections: on the plastic side pressing joint, on the metal side male or female thread according to DIN EN 10226-1 or smooth tube connection according to DIN 3387-1