



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4360BT0573
Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Gas fittings: Gas flow monitor (4360)
Product description <i>Produktbezeichnung</i>	Profipress G gas flow monitor for gas installations with overflow opening
Model <i>Modell</i>	2641.2HT
Test reports <i>Prüfberichte</i>	Type testing: 165 603a T0/18269 from 07.12.2023 (GWI)
Test basis <i>Prüfgrundlagen</i>	DIN 30652-1 (01.06.2021) DIN 30652-3 (01.06.2021)

Date of Expiry / File No. 19.12.2028 / 23-0653-GNV
Ablaufdatum / Aktenzeichen

29.01.2024 Bd A-1/2 *i.A. 20-72*
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
Fuel gases according to G 260	according to DIN EN 437

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
2641.2HT (M/K)	Operating pressure: 15...100 mbar Nominal flow rate: 2,0/3,2/4,8 m ³ /h Nominal diameter: DN 25	
2641.2HT (M/K)	Operating pressure: 15...100 mbar Nominal flow rate: 4,8/8,0 m ³ /h Nominal diameter: DN 32	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Permissible ambient temperature range: -20...+60 °C

Installation position: horizontally (type K) or vertically upwards (type M)

Connection type: entry side external thread R 1 and R 1 1/4 according to DIN EN 10226-1 press connector on the output side

"Profipress G with SC-Contur" according to DVGW-G 5614

HTB 650 °C up to pressure level GT 1