



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6102BT0071

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Stop valves for drinking water: Ball valve (6102)
Product description <i>Produktbezeichnung</i>	Easytop Inox-ball valve made of stainless steel, with compression connections and SC-Contur not pressed leaky
Model <i>Modell</i>	2370
Test reports <i>Prüfberichte</i>	Laboratory control test: 120003396-21-IB from 19.08.2021 (MPM) Supplement test: 120003824-E from 25.04.2012 (MPM) Type testing: 120002871-2 from 07.02.2008 (MPM)
Test basis <i>Prüfgrundlagen</i>	DVGW W 570-1 (01.03.2013) DIN EN 13828 (01.12.2003) UBA BWGL-Metalle: Grundwerkstoffe (11.01.2023) UBA ELASTOM (16.03.2016) UBA KTW-BWGL (07.03.2022) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	08.02.2028 / 23-0040-WNV

70028-04-A-DE

20.03.2023 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

G. Schmidt



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
2370	Noise emission class: I Nominal diameter: DN 15	
2370	Noise emission class: I Nominal diameter: DN 20	
2370	Noise emission class: I Nominal diameter: DN 25	
2370	Noise emission class: I Nominal diameter: DN 32	
2370	Nominal diameter: DN 40	
2370	Nominal diameter: DN 50	

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

both-sided compression connection system "Sanpress Inox SC-Contur" (DW-5801BL0035)

DVGW