



CERT

DVGW type examination certificate


DVGW-Baumusterprüfzertifikat

DG-7521CP0098

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	material transition fittings: transition on PE-HD for gas pipes (7521)
Product Description <i>Produktbezeichnung</i>	material transition fitting made of plastic on PE-HD (PE 80, PE 100, PE-Xa)
Model <i>Modell</i>	Geopress K
Test Reports <i>Prüfberichte</i>	laboratory control test: 120000428-19-3 from 16.07.2019 (MPM) type testing: 120004741-1 from 11.04.2016 (MPM)
Test Basis <i>Prüfgrundlagen</i>	DVGW G 5600-2/(VP) (01.09.2015)

Date of Expiry / File No. 14.04.2025 / 21-0107-GNU
Ablaufdatum / Aktenzeichen

20.07.2021 Rie A-1/2 
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

 **DAkkS**
Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
fuel gases according to G260: 03.2013	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Geopress K	nominal diameter: 32 mm	
Geopress K	nominal diameter: 40 mm	
Geopress K	nominal diameter: 50 mm	
Geopress K	nominal diameter: 63 mm	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Maximum operation pressure: 5 bar (PE 80, SDR 11), 8 bar (PE-Xa, SDR 11) or 10 bar (PE 100, SDR 11) resp. for the transition joints maximum 5 bar

Connections: on the plastic sides pressing joint, on the metal side male or female thread according to DIN EN 10226-1 or smooth tube connection according to DIN 3387-1