



DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8511CS0016
Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Installation systems and system joints (PN 10): pipe joint for pipes in drinking water installation systems (8511)
Product description <i>Produktbezeichnung</i>	transition fitting as compressing fitting made of silicon bronze with SC-Contour (unpressed and leaking)
Model <i>Modell</i>	Megapress: 4213.2, 4211.4, 4212.4
Test reports <i>Prüfberichte</i>	Type testing: 122001078-PB from 07.10.2025 (MPM) Laboratory control test: 20000428-21-3IB + ...-3PB from 12.08.2021 (MPM) Type testing: 120004890 from 24.01.2017 (MPM)
Test basis <i>Prüfgrundlagen</i>	DVGW W 534-(P) (01.07.2015) DVGW CERT ZP 8500 (01.01.2017)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	24.01.2027 / 25-0751-WNU

70028-04-A-DE

20.02.2026 Bn A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

A. W. Z.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvlgw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
Megapress	Diameter: 21,3 mm	
Megapress	Diameter: 26,9 mm	
Megapress	Diameter: 33,7 mm	
Megapress	Diameter: 42,4 mm	
Megapress	Diameter: 48,3 mm	
Megapress	Diameter: 60,3 mm	

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

range of application: Drinking water cold (PWC) / Drinking water warm (PWH) for stainless steel pipes
Material: Silicon bronze (CC246E / CuSi4Zn9MnP)

Compatible pipes for Megapress press connection: Galvanized steel pipes according to DIN EN 10255, 1/2-2 inches, stainless steel pipes (material no. 1.4301, 1.4306, 1.4307, 1.4401, 1.4404, 1.4541, 1.4550, 1.4571) in accordance with DIN EN 10216-5 and DIN EN 10217-7, 1/2-2 inches

System transition (4213.2) to pipes:

-Stainless steel tube (1.4521) for drinking water installation, model: Sanpress Rohr 1.4521, Viega Technology GmbH & Co. KG, Viega Platz 1, D-57439 Attendorn (DVGW Registration Number DW-7301BS0375)

-Stainless steel tube (1.4401) for drinking water installation, model: Sanpress Rohr 1.4401, Viega Technology GmbH & Co. KG, Viega Platz 1, D-57439 Attendorn (DVGW Registration Number DV-7301BS0411)

-in accordance with DVGW worksheet GW 541

-copper pipes in accordance with DVGW worksheet GW 392

The suitability for drinking water hygiene is verified by a "Hygiene Conformity Certificate" in accordance with the currently valid legal basis.

DVGW
CERT