



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-8617CP0092

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Plastic fittings and compression fittings: mechanical joint compression fittings for water supply systems (8617)
Product description <i>Produktbezeichnung</i>	compression fittings made of plastic for pipes made of PE-HD and PE-Xa for water supply
Model <i>Modell</i>	Geopress K
Test reports <i>Prüfberichte</i>	Type testing: 122000416-PB from 24.05.2023 (MPM) UBA Guideline/BWGL: Z-346586-21-Hy112 from 20.03.2023 (WHY)
Test basis <i>Prüfgrundlagen</i>	DVGW GW 335-B3/(P) (01.09.2011) DVGW GW 335-B3/B2 (01.04.2013) UBA BWGL-Metalle: Grundwerkstoffe (11.01.2023) UBA ELASTOM (16.03.2016) UBA KTW-BWGL (07.03.2022) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	14.04.2029 / 24-0213-WNV

10/2018-04-A-DE

07.05.2024 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Geopress K	Nominal diameter: 25 mm	Allowable operating pressure PFA 16 bar
Geopress K	Nominal diameter: 32 mm	Allowable operating pressure PFA 16 bar
Geopress K	Nominal diameter: 40 mm	Allowable operating pressure PFA 16 bar
Geopress K	Nominal diameter: 50 mm	Allowable operating pressure PFA 16 bar
Geopress K	Nominal diameter: 63 mm	Allowable operating pressure PFA 16 bar

Hints of Utilization / Remarks***Verwendungshinweise / Bemerkungen***

Fittings tested with pipes made from polyethylene PE 80 and PE 100 according to DVGW GW 335-A2 and pipes made from PE-Xa according to DVGW GW 335-A3