



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DG-4360CL0453
Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Distributor <i>Vertreiber</i>	Viega GmbH & Co. KG Viega Platz 1, D-57439 Attendorn
Product Category <i>Produktart</i>	Gas fittings: Gas flow monitor (4360)
Product description <i>Produktbezeichnung</i>	Gas flow monitor Type K with overflow opening for gas installations
Model <i>Modell</i>	2647.1S/2S
Test reports <i>Prüfberichte</i>	Type testing: 153763aT0/16603 from 22.12.2010 (GWI) Laboratory control test: 153763a K2022 from 03.11.2022 (GWI)
Test basis <i>Prüfgrundlagen</i>	DVGW VP 305-1 (01.12.2007)

Date of Expiry / File No. 22.12.2025 / 22-0636-GNV
Ablaufdatum / Aktenzeichen

07.03.2023 Kir A-1/2
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

G. Schmidt

 **DAKKS**
Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993
www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
Fuel gases according to G 260: 03.2013	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
2647.1S/2S	Operating pressure: 15 ... 100 mbar Nominal flow rate: 2,0/3,2 m ³ /h Nominal diameter: DN 20	
2647.1S/2S	Operating pressure: 15 ... 100 mbar Nominal flow rate: 2,0/3,2/4,8 m ³ /h Nominal diameter: DN 25	
2647.1S/2S	Operating pressure: 15 ... 100 mbar Nominal flow rate: 4,8/8,0 m ³ /h Nominal diameter: DN 32	
2647.1S/2S	Operating pressure: 15 ... 100 mbar Nominal flow rate: 8,0/12,8 m ³ /h Nominal diameter: DN 40	
2647.1S/2S	Operating pressure: 15 ... 100 mbar Nominal flow rate: 8,0/12,8 m ³ /h Nominal diameter: DN 50	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
2647.1S	Connections: Inlet with female thread Rp..., outlet with male thread R..., each acc. to DIN EN 10226-1
2647.2S	Connections: Inlet with female thread Rp..., outlet with male thread R..., each acc. to DIN EN 10226-1

Hints of Utilization / Remarks
Verwendungshinweise / Bemerkungen

Ambient temperature: -20 ... +70 °C
Position: Horizontal or vertical (upright)

DVGW